

OM SAI RAM

SAINI FIRE SYSTEMS

D-17, H.No-211, Rohini Sec-3, Delhi - 110085

Contact No.: 8010526652, 9540346417

Email: sainibellfiresystems@gmail.com,

Website: www.sainifiresystems.in GSTIN: 07BVIPK1923Q1Z4

Fire Protection Engineers & Contractors


Ref. No....SFS /TC/410-22/23

Dated. :12-07-2022

FIRE AUDIT REPORT

Name of the Hospital: APRASU AYURVEDA PANCHKARMA HOSPITAL (FIRE AUDIT REPORT)

S No	PART & PARA IN DETAIL AUDIT REPORT	OBSERVATION	RECOMMENDATION	ACTION BY
1	Fire Extinguishers	Fire Extinguishers of ABC type are installed in the entire centre area	Fire extinguishers placement has been rechecked based on hazards and type of fire as per IS:2190. Access to extinguishers to be kept obstruction free for quick response.	We check the fire extinguisher cylinder every fortnight and if any problem is found than immediately call the person of the company.
2	Emergency Fire Exit Plan	They have placed proper Fire exit plan over there, suggested for emergency duty roster to be prepared and implemented	Printed copies of the emergency fire escape plan are provided and efforts are made to remove any obstructions on the way out into the centre premises.	We follow the recommendation religiously.
3	Means of escape and open space around the building	Main gate round the clock manned by CCTV cameras. In case of fire emergency the fire fighting vehicles can approach the building from front side only.	A clear access way must be maintained in front of the centre gate for speedy movement fire fighting appliances. Approach road may be kept free for movement of fire vehicles in case of fire emergency.	Someone in our staff member takes care throughout the day to ensure that there is no obstruction at any emergency time during fast movement and if any obstruction is found than it is removed immediately.
4	Life safety, Directional signage inside the centre	Emergency exit signage's provided in entire centre area	Direction to exit must be conspicuously and unambiguously marked with exit signage's.	We have put up proper signage of fire exit and escape plans throughout the centre.
5	Wet Riser & Automatic sprinkler system	3 Wet riser & 2 hydrant are installed in this centre & they are working properly.	Sufficient fire fighting system are installed in the centre. the maintenance of these equipments should be done regularly.	Yes, we also maintain fire fighting system maintenance with AMC of these equipments.



6	Centre Areas	Good housekeeping being maintained throughout centre area. Proper color coding, waste bins should be provided wherever necessary.	Good housekeeping practices should be continued and records should be maintained.	we have trained housekeeping staff member along with another staff for all recommended checks.
7	Basic first Aid & Fire Fighting Training	During audit it was realized that staff working in centre have basic knowledge of first aid firefighting equipments like wet riser, fire extinguishers, alarm system, hydrant system.	All the employees & staff who are always present in the centre are required to be regularly trained in various aspects of fire prevention, fire protection & fire extinction including handling of first aid & fire fighting equipments.	We given training to escape from any emergency or to use fire fighting equipments like- wet riser, alarm system, fire extinguishers, hydrant system.

FOR SAINI FIRE SYSTEMS

