

FMS 3: Lack of plans of early detection, abatement and containment of fire and non-fire emergencies exercise of HIRA is also could not be evidenced

Plan of action for Fire & Non Fire Emergencies

We strictly follow the fire safety tips and take precautions as per the day care center like fire extinguishers are installed according to the clinic space. It is our best effort that we follow all the safety measures of NABH & trying to conduct exercise of HIRA & taken all necessary action, which we check and follow through the check list.

Parameters on which we follow Fire Safety Measures:

- Fire Fighting system like Fire Extinguisher of TYBE ABC is installed as per clinic space
- Maintaining the operational and refilling of extinguishers through tracking register (Copy Attchd)
- Providing adequate Fire Safety training of employees on time (Video Attchd)
- The fire exit plan is displayed in a proper manner which shows if any untoward incident occurs, then how to get out of it
- Fire Exit Signage on entire clinic area along with Fire Escape Plan well illuminated as per NABH Guidelines
- Emergency illumination system in case power goes. i.e. Inverter installation (Pic Attchd)
- Properly installed smoke detector for early warning and alert us to avoid any incidence
- Designated place for assembly of patients and staff in case of fire i.e. Fire Assembly point signage outside clinic area
- Emergency illumination system in case power goes
- Mock fire drill records and schedule of conduct of drills
- As per norms of NABH Standards mentioned, we have following the entire mandatory requirement for fire safety


Jeena Sikho Lifecare Ltd.
H. No. 432, Ground Floor,
Prahladpur Banger,
Rohini, New Delhi-110042



Fire Extinguisher



Radium Fire Exit



Fire Escape Plan Layout



Inverter for alternate power



Another Fire Exit Signage



Fire Assembly Signage outside Clinic Area



No Smoking Zone inside clinic premises



Smoke Detector