

OM SAI RAM

# SAINI FIRE SYSTEMS

D-17,H.No-211, Rohini Sec-3, Delhi – 110085

Contact No.: 8010526652,9540346417

Email: [sainibellfiresystems@gmail.com](mailto:sainibellfiresystems@gmail.com),

Website. : [www.sainifiresystems.in](http://www.sainifiresystems.in) GSTIN. : 07BVIPK1923Q1Z4

**Fire Protection Engineers & Contractors**

Ref. No- SFS/TC/410-22-23

Dated- 18-06-2022

M/S **APRASU AYURVEDA PANCHKARMA CENTRE**

( B-1087-88, ROHINI SECTOR-1 DELHI-110085)

## **FIRE SAFETY CERTIFICATE**

This is to certify that M/S APRASU AYURVEDA PANCHKARMA CENTRE B-1087-1088 ,Rohini sector-1, Delhi -110085, All floors owned by Dr. Simran Arora has made satisfactory fire safety arrangements as per Requirements, Said we have no objection from fire point of view, with the condition of fire safety measures , trained staff and firefighting system ( Automatic fire alarm system , Automatic smoke detectors , wet risers ,sprinklers ,Hydrants is fully installed and also Building have two different stair case for Evacuation) During inspection they are available in good working conditions.

During inspection Any type of Nonfunctioning of the firefighting systems will occur responsibility will be of owner / management .The validity of fire safety certificate is one year.ie,18 jun 2022 to 17 jun 2023.

SAINI FIRE SYSTEMS



**SAINI FIRE SYSTEMS** 

OM SAI RAM

# SAINI FIRE SYSTEMS

D-17, H.No-211, Rohini Sec-3, Delhi - 110085

Contact No.: 8010526652, 9540346417

Email: [sainibellfiresystems@gmail.com](mailto:sainibellfiresystems@gmail.com),

Website: [www.sainifiresystems.in](http://www.sainifiresystems.in) GSTIN: 07BVIPK1923Q1Z4

**Fire Protection Engineers & Contractors**

Ref. No- SFS/TC/410-22-23

Dated- 18-06-2022

## TO WHOM IT MAY CONCERN

This is to certify that.

We have Supply installation testing & commissioning your Fire hydrant, fire sprinkler, smoke detector, fire alarm systems, hose reel complete & fire extinguisher etc. and presently that they all are working properly.

M/S. **APRASU AYURVEDA PANCHKARMA CENTRE.**

Address: B- 1087-88, Rohini Sector-1, Delhi, 110085

and we found that the all fire accessories are in working condition as on Date..

T&C Issued by Mrs SAINI FIRE SYSTEMS

