



DELHI POLLUTION CONTROL COMMITTEE
DEPARTMENT OF ENVIRONMENT (GOVT. OF NCT OF DELHI)
4TH & 5TH FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-6
visit us at <http://dpccocmms.nic.in>

Noise Monitoring Report

Result No- DPCC/Comm/N/6581/27

15/04/2021

Date:13/04/2021

1. Name & Address of Ind/Unit : M/s.Sandhyashi Hospital
B 48 Sector 5 Bawana Industial Area
Delhi--110039

2. Date of Monitoring : 08/04/2021

3. Year of Manufacture : After Jan 2005 but upto 1000KVA

4. Time of Monitoring : 15 : 35

Results :

S. No.	Location	Noise Level	Remarks	Standard
1.	Ambient Noise Level in dB(A)	60.1	D.G. Set(s) Non-Operational	
2.	Ambient Noise Level in dB(A)	69.8	D.G. Set(s) Operational	
3.	Noise Level at 1.0 m away from the enclosure surface in dB(A)	74.2	D.G. Set(s) Operational	<=75

Note

=> The premises is used as Hospital

=> The unit has 1 D.G.Set(s) of 1.6 KVA bearing engine no. EBK2000AC with stack height without stack .

=> D.G.Set of the unit is installed in an acoustic enclosure (portable petrol driven) at front side in the premises.

=> D.G.Set monitored is meeting the permissible limit as per the G.S.R.371(E) dated 17/05/2002 and amended till date. However Ambient Air Quality Standards in Respect of Noise as mentioned in Schedule III of the Environment(protection) Rules,1986 is meeting

SCIENTIST (D)

ENV.ENGINEER
TRILOK CHAND
AEE