



(Estd. 1995)

ISO-9001:2015 Certified Lab

# Welcome Food Laboratory (Regd.)



4132, IIIrd Floor, 306-B, Near PNB Bank,  
Naya Bazar, Delhi-110006  
Phone No.: 011-43550326  
M.: 9891326685, 8800581580  
E-mail : welcomefoodlab@gmail.com

## TEST REPORT

<b>Issued to:-</b> Sanidhyashi Hospital	Report No:	WFL/11592A
<b>Add:-</b> B-48 industrial area sector-5 bawana Delhi 110039	Report Date:	02/02/2022
	Sample Receive Date:	31/01/2022
	Test started on	01/02/2022
	Test Completed	02/02/2022

**Sample Particulars:**

Nature of the sample & No.	: Water (One Sample)
Brand Name, if any	: None
Batch No. & Manufacturing Date	: None
Quantity & Packaging	: 1.0 Liter
Method of Sampling	: Sample is provided by company person

**ANALYSIS CERTIFICATE OF WATER**

No	Parameters	Test Report	Max. Limit as per IS:10500(2012)	Protocol
1.	Colour,Hazen	1.51	5 Max.	IS:3025 (P-4)
2.	Odour	Unobjectionable	Unobjectionable	IS:3025 (P-5)
3.	Taste	Agreeable	Agreeable	IS:3025 (P-7)
4.	Turbidity NTU	2.10	5 Max.	IS:3025 (P-10)
5.	pH Value	8.40	6.5-8.5	IS:3025 (P-11)
6.	Total Hardness(as CaCO <sub>3</sub> )mg/L	03.60	300 Max.	IS:3025 (P-21)
7.	Iron (as Cl),mg/L	0.20	0.3 Max.	FL/SOP/C-14
8.	Chloride (as Cl),mg/L	33.10	250 Max.	IS:3025 (P-32)
9.	Residual Free Chlorine,mg/L	< 0.21	0.2 Min.	IS:3025 (P-26)
10.	Total Dissolved Solids, mg/L	112.00	500 Max.	IS:3025 (P-16)
11.	Calcium (as Ca), mg/L	21.65	75 Max.	IS:3025 (P-40)
12.	Magnesium (as Mg), mg/L	14.10	30 Max.	IS:3025 (P-46)
13.	Sulphate as SO <sub>4</sub> Mg/L	20.15	200 mg /L	IS:3025 (P-52)
14.	Fluoride as ( ca) mg/L	0.021	1.50mg/L	IS:3025 (P-60)
15.	Nitrate as (ca) mg/L	26.70	200.0Max.	IS:3025 (P-34)
16.	Copper as (cu) mg/L	0.40	1.50Max.	IS:3025 (P-42)

Opinion. Sample Parameters Confirm the as per IS: 10500-2012 limits

Checked by

Page 01 of 02

  
(Authorized Signatory)

Welcome Food Laboratory

**NOTE:** The laboratory accepts the responsibility for content of report. The result contained in this report related only to the sample tested. This report is intended only for your guidance and not for legal purpose or for advertisement. This report shall not be reproduced except in full with the written approval of this organization. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report be communicated in writing